

2023

January

MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
26	27	28	29	30	31	01
02	03	04	05	06 TK Elevator onsite for unresponsive elevator	07	08
09	10	11	12	13 Meeting with new TK Elevator Account Manager to discuss ongoing elevator issues.	14	15 Pool Resurfacing - prep work and draining pool
16 Pool Resurfacing Worthington Security onsite to reset camera software app Board Meeting 5:00pm	17 Pool Resurfacing TK Elevator onsite for unresponsive elevator	18 Pool Resurfacing & Filtered Water Filling Pool. Fish Window Cleaning onsite to clean balcony glass, lobby glass and social room sliders.	19 Filtered Water Filling Pool	20 Chemicals Added to Pool	21 Chemicals Added to Pool	22 Pool Is Open
23	24	25	26	27 TK Elevator onsite for door staying open on ground floor occasionally and fix light on PH floor elevator button.	28 Volunteers did a deep clean of the pool furniture.	29
30	31	Notes: Crystal Pools did an excellent job on the pool resurfacing. Crystal Pools is also getting the pool pit door fixed. Thanks to all the volunteers who gathered to do a deep clean of the pool furniture. The job was complete the job in about 1-1/2 hours. The issue with the elevator going non responsive was due to a loose wire that the door hold button would hit when it was used. Once the techs talked with Sharon and listened to what has been happening, they found the loose wire.				