

# 2022

# May

MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
25	26	27	28	29	30	01
02	03	04	05	06 Sound of water heard using elevator in the PM hours. Discovered water was in the elevator pit.	07 Sound of water heard using elevator due to high water in the elevator pit.	08 Sound of water heard using elevator due to high water in the elevator pit.
09 Paradise Plumbing onsite to drain the elevator pit. Blue Water Electric onsite to check electrical in elevator pit.	10 Hillman onsite to do site survey for generator.	11 Elevator Sump Pump - new float switch / oil dectector ordered from Paradise Plumbing.	12	13	14	15
16	17	18	19 Pool Heater not working. Crystal Pools onsite to check it.	20 Crystal Pools onsite to check water in pool pit due to king tides. Sump pump needs replaced.	21	22
23 Membership Meeting / Board Meeting 5pm. Paradise Plumbing onsite to camera the roof drains. TK onsite to determine fix for elevator door hatch.	24 Nouveau National onsite to inspect elevator cab for quoting purposes.	25 Paradise Plumbing onsite to install new float in elevator pit. Nouveau National onsite to inspect elevator cab.	26	27 Pipe lining company onsite to inspect sewer pipes in garage for quoting purposes.	28	29 Memorial Day Cookout
30	31 Pool Leak Company onsite to look for pool leak.	Notes: Elevator pit sump pump stopped working and water filled the pit. Paradise Plumbing pumped out the water and Blue Water checked on the electrical. Paradise Plumbing connected a temporary float and the part needed was ordered. <b>Someone messed with the pool heater and changed settings and other things causing it not to work! No one is to touch the pool heater!</b> Crystal Pools says we have a pool leak and he is arranging for a leak company to come test the pool. A new combo packlock has been ordered for the pool heater gate and the Mike Bisaha fixed the gate latch. TK discovered damage to the entire wood elevator cab. Quotes needed to change cab to metal. Pool leak found in deep end gutter. Waiting on quote for repair.				