

# 2025

# July

| MONDAY                            | TUESDAY | WEDNESDAY  | THURSDAY   | FRIDAY | SATURDAY | SUNDAY |
|-----------------------------------|---------|--|--|--------|----------|--------|
| 30                                | 01      | 02<br>APlus Concrete Restoration onsite for PH5 leak.  | 03   | 04     | 05       | 06     |
| 07                                | 08      | 09<br>Exclusive Contrators onsite for ceiling repair in PH5.   | 10<br>Fish Window cleaning onsite to clean the glass railings and the lobby windows. | 11     | 12       | 13     |
| 14                                | 15      | 16   | 17   | 18     | 19       | 20     |
| 21<br>No Board Meeting this Month | 22      | 23   | 24   | 25     | 26       | 27     |
| 28                                | 29      | 30   | 31   | 01     | 02       | 03     |
| 04                                | 05      | <b>Notes:</b><br>The leak in unit PH5 looked old and it was determined that the waterproofing of the top of the back patios in March fixed the issue. Exclusive Contractors repaired the ceiling crack caused by the leak. |  |        |          |        |