

2019

September

MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
26	27	28	29	30	31	01 Storm preparation completed
02	03	04	05	06	07 Alarm Issues. All pool furniture is back in place.	08 Alarm Issues
09 Alarm Issues Genset was called and discovered a phone line not working that was tripping the alarm. Comcast reset the voice modem and all lines are working now.	10	11	12	13	14	15
16 No Board Meeting this Month. New Stairwell Lights Ordered	17	18	19	20 Blue Water Electric started installation of new stairway lights.	21 Blue Water Electric finished installation of new stairway lights.	22
23	24	25 Common areas treated for cockroaches. 5th floor trash room molding replaced.	26 Insurance Inspection. Trash chute cleaned and sanitized. Bees found on roof A/C unit treated.	27	28	29
30	01	Notes: We were so fortunate that Hurricane Dorian didn't do any major damage in our area. Genset identified our 754-307-1058 phone line as not working. We have 4 phone lines with Comcast. The stairwell lights installed last year were a complete LED light unit. As the units failed, some of the power supplies for the light caused the circuit breaker to trip. A decision was made to change out the lighting to one used a LED light bulb rather than the complete LED light unit.				