

2025

September

MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
01	02 Worthington Security onsite for camera system computer issue.	03	04	05	06 TK Elevator onsite for elevator out of service	07
08	09	10	11	12	13	14
15 Board Meeting 5:00pm	16	17	18	19	20	21
22 Paul Bange Roofing onsite to repair south stairwell skylight. Bluewater Electric onsite for flag light and exit signs. TK Elevator onsite for elevator out of service	23	24	25	26	27	28
29	30	01	02	03	04	05
06	07	Notes: Both times the elevator went out of service this month was due to something in the track blocking the door from closing. The second time the technician could tell a belt needed to be replaced and it has been ordered.				